



Overall Rating: PASSED

Report No : 2020121501

Applicant : **HZR MADENCİLİK VE NAKLİYAT SANAYİ TİCARET LİMİTED ŞİRKETİ**

Applicant Address : FEVZİ ÇAKMAK MAH. 10758. SK. NO: 11 F KARATAY/ KONYA

Contact Person : Murat Ata

Contact Telephone : 0507 783 05 50

Sample Accepted on : 04.12.2020 : 11:40

Report Date : 15.12.2020

Total number of pages : 5 (Pg)

Sample ID: COTTON PLASTER

	TEST	METHOD	RESULT
*	Thermal Insulation - Determination of Steady Heat Resistance and Related Properties - Enclosed Hot Plate Device	ISO 8302	0.058 W/(m.K)



Seal



Customer Representative
Hasan KUTLU



Laboratory Manager
Hava Sarıaydın

EUROLAB[®] (TÜRCERT TEKNİK KONTROL VE BELGELENDİRME A.Ş.)

It is prohibited to change any and all versions of this document in any manner whatsoever. In case of a conflict between the electronic version (e.g. PDF file) and the original paper version provided by EUROLAB[®], the latter will prevail.

TÜRCERT Teknik Kontrol ve Belgelendirme A.Ş. disclaim liability for any direct, indirect, consequential or incidental damages that may result from the use of the information or data, or from the inability to use the information or data contained in this document.

The contents of this report may only be transmitted to third parties in its entirety and provided with the copyright notice, prohibition to change, electronic versions' validity notice and disclaimer.

Environment

The requirements and standards apply to equipment intended for use in

X	Residential (domestic) environment
X	Commercial and light-industrial environment
X	Industrial environment
X	Medical environment



Thermal Insulation - Determination of Steady Thermal Resistance and Related Properties


Method

The thermal resistance of the samples was measured with a heat flow meter for 30x30 cm samples as described in ISO 8302 (Figure 1). The device consists of a central hot plate with a cold plate above and below. Circular heat flow meters with a diameter of 10 cm are located centrally on the bottom of the top plate, on both sides of the central plate and on the top of the bottom plate. These heat flow counters are embedded in a neoprene sheet that is the same thickness as the counters and is as large as the area of the plates. In the middle of each plate side, extremely thin Cu / Co thermocouples are glued against the heat flow counters. Samples are then mounted between the top plate and the center plate and between the bottom plate and the center plate. All of them are finally packed in a thermally insulated box to create close to adiabatic conditions around the installation. Before the measurements start, heat flow meters are recalibrated using reference samples of the EU's BCR.

The temperature difference between the thermostatic bath that keeps the upper and lower cold plate at temperature and the thermostatic bath that keeps the central hot plate at temperature is set to 10 ° C. The temperatures and heat fluxes on both surfaces of the samples are not fixed, all data are recorded in 10 time intervals and stored on the hard disk. All calculations are done in Excel. Values are converted in averages lasting three hours and the resistance is calculated using the equation below.

$$R = \frac{2\Delta\theta}{C_1 E_1 + C_2 E_2}$$

C_1, C_2	Calibration constants of heat flow meters W / (m ² .mV))
E_1, E_2	Electric voltage difference measured on heat flow meters at mV
$\Delta\theta$	Temperature difference on samples in K (measured with Cu / Co thermocouples)



Results of the measurement

Sample	Thickness m	Vol. humidity rate %m ³ /m ³	Average temperature °C	Temperature difference °C	Thermal Resistance m ² .K/W ⁽¹⁾
1	0.02	0	1.5	9.0	0.50 ²
			11.5	9.2	0.58 ⁷
			21.4	9.2	0.58 ⁰
			31.3	9.3	0.57 ²
			41.2	9.2	0.56 ⁰
2	0.02	0	1.6	8.9	0.60 ⁷
			11.6	9.1	0.59 ⁰
			21.5	9.2	0.58 ⁰
			31.4	9.2	0.57 ²
			41.3	9.2	0.56 ²
3	0.02	0	1.6	9.2	0.60 ⁵
			11.6	8.7	0.59 ²
			21.4	9.3	0.58 ¹
			31.4	9.4	0.58 ²
			41.3	9.2	0.57 ²

⁽¹⁾ The last number in the superscript is not precise (not sure)

Sample	$\frac{\partial q}{q}$ %	$\frac{\partial \theta}{\theta}$ %	$\frac{qR_n}{\Delta \theta}$ %	Maximum Uncertainty %	Most Possible Uncertainty %
1	1.5	0.55	1	3.1	1.9
2	1.5	0.55	1	3.1	1.9
3	1.5	0.55	1	3.1	1.9



Thermal conductivity at different average temperatures

These are given in the table below:

Average temperature °C	Thermal Conductivity W/(m.K)
-10	0.049
0	0.050
10	0.055
20	0.057
30	0.063
50	0.066
100	0.071
200	0.083
300	0.094
400	0.106
500	0.117

The average thermal conductivity in COTTON PLASTER then reaches **0.058 W / (m.K)**.

In the test environment, the relative humidity in the environment is 50%.

In the test environment, the air temperature is about 21 degrees Celsius.

***** End of Report *****

